



Dayton

D211004

CAUTION

- + UNIT SHALL BE GROUNDED IN ACCORDANCE WITH N.E.C.
- + POWER MUST BE OFF WHILE SERVICING.

NOTES

1. WIRING TO SENSOR OR SELECTOR TO BE IN SEPARATE CONDUIT OR TO BE USED WITH SHIELDED CABLE.
2. 0 TO 99 TERMINAL BLOCK 24 VOLT, LETTERED TERMINAL BLOCK HIGH VOLTAGE.
3. USE COPPER CONDUCTORS ONLY, 60 DEGREE CELSIUS MINIMUM FOR FIELD CONNECTIONS.
4. TORQUE FIELD WIRING TERMINALS AND SUPPLY GROUND LUG TO 20 IN. LBS.
5. FIELD WIRED _ _ _ _ , FACTORY SUPPLIED AND WIRED _ _ _ _ .

FACTORY SUPPLIED COMPONENTS

FIELD SUPPLIED COMPONENTS

- S2 SUPPLY FAN SWITCH
- S3 HEAT SWITCH