

# Stock No. 1MBE7

Job Name: Mark: Submitted By: Date:12/15/2025

CSA Certified Motor

## **Assembled Centrifugal Belt-Drive Upblast Exhaust Ventilator**



Designed for use in restaurants, schools, commercial, and industrial applications to exhaust contaminated air from kitchen range hoods, up and away from the roof. Leakproof, spun aluminum construction features a fully rolled windband for increased stability.

- Aluminum backward inclined, nonoverloading centrifugal wheel design
- Maximum inlet air temperature: 300° F
- NEMA 1 junction box located in motor enclosure
- Optional NEMA 1 and 4 disconnects available
- Sealed pillow block bearings
- UL/cUL 705 Listed for Power Ventilators
- UL/cUL 762 Listed for Restaurant Exhaust Appliances
- Air handling quality bearings meet minimum of L10-100,000 hours






A Square

Α	В	С	D
22 in	24 7/8 in	25 1/8 in	17 3/8 in

## **Performance Characteristics**



## **Construction Features**

Impeller Diameter (Typ.)	11 1/4 in			
Impeller Type	Backward Inclined Centrifugal			
Impeller Material	Aluminum			
Max Inlet Temp	300 °F			
Bearing Type	Sealed Pillow Block			
Drive Package Description	Drives Assembled			
Warranty Length	1 Year			

#### **Motor Information**

Motor Item Number	1AGG2
Voltage	115/208-230
Hertz (Cycle)	60 Hz
Motor Phase	1
Motor Enclosure	Open Drip Proof
RPM	1,725 rpm
Full Load Amps	5.8/3.1-2.9

### Other Components

Component	Description	Item #
Fan Description	Exhaust Fan	_
Belt	A20 (QTY: 1)	3VU39
Driver Sheave	1VP44x1/2	3X275
Driven Sheave	AK41x3/4	5RJC2

## **Air & Sound Performance**

Motor HP	Max BHP	Fan RPM	CFM @	0.000" SP	0.125" SP	0.250" SP	0.375" SP	0.500" SP	0.625" SP	0.750" SP	0.875" SP	1.000" SP	1.250" SP
1/3	1/3 0.35	1820	CFM	1549	1505	1459	1406	1350	1293	1234	1171	1106	900
1/3 0.33	0.33 1020	Sones	14.3	13.7	13.4	12.7	12.4	12.0	11.6	11.2	10.6	10.1	

Performance certified is for installation type A: Free inlet, Free outlet. Power rating (BHP) does not include transmission losses. Performance ratings do not include the effects of appurtenances (accessories). The sound ratings shown are loudness values in fan sones at 5 ft. (1.5 m) in a hemispherical free field calculated per AMCA Standard 301. Values shown are for installation type A: Free inlet hemispherical sone levels.

Catalog 405, January 2010

#### **Operating Range of Drive Package**

Turns Open	FRPM @ 0 TO	FRPM @ 1/2 TO	FRPM @ 1 TO	FRPM @ 1 1/2 TO	FRPM @ 2 TO	FRPM @ 2 1/2 TO	FRPM @ 3 TO	FRPM @ 3 1/2 TO	FRPM @ 4 TO	FRPM @ 4 1/2 TO	FRPM @ 5 TO
Approx. FRPM	1820	1783	1736	1690	1644	1597	1551	1505	1458	1412	1366