

Stock No.

Job Name: Mark:

Submitted By: Date:11/3/2025


CSA Certified Motor

Assembled Centrifugal Belt-Drive Upblast Exhaust Ventilator




Designed for use in restaurants, schools, commercial, and industrial applications to exhaust contaminated air from kitchen range hoods, up and away from the roof. Leakproof, spun aluminum construction features a fully rolled windband for increased stability.

- Aluminum backward inclined, nonoverloading centrifugal wheel design
- Maximum inlet air temperature: 300° F
- NEMA 1 junction box located in motor enclosure
- Optional NEMA 1 and 4 disconnects available
- Sealed pillow block bearings
- UL/cUL 705 Listed for Power Ventilators
- UL/cUL 762 Listed for Restaurant Exhaust Appliances
- \bullet Air handling quality bearings meet minimum of L10-100,000 hours







Α	В	С	D
19 in	24 7/8 in	25 1/8 in	17 3/8 in

Performance Characteristics

No Fan Curve Available.

Construction Features

Impeller Diameter (Typ.)	11 in			
Impeller Type	Backward Inclined Centrifugal			
Impeller Material	Aluminum			
Max Inlet Temp	300 °F			
Bearing Type	Sealed Pillow Block			
Drive Package Description	Drives Assembled			
Warranty Length	1 Year			

Motor Information

Motor Item Number	1AGG1				
Voltage	115/208-230				
Hertz (Cycle)	60 Hz				
Motor Phase	1				
Motor Enclosure	Open Drip Proof				
RPM	1,725 rpm				
Full Load Amps	6.2/2.8-3.1				

Other Components

Component	Description	Item #
Fan Description	Exhaust Fan	_
Belt	3L180 (QTY: 1)	3L180
Driver Sheave	1VP30x1/2	5UHP7
Driven Sheave	AK32x3/4	14A167

Air & Sound Performance

Motor HP	Max BHP	Fan RPM	CFM @	0.000" SP	0.125" SP	0.250" SP	0.375" SP	0.500" SP	0.625" SP	0.750" SP	0.875" SP	1.000" SP	1.250" SP
1/4	1/4 0.25 1725	CFM	1260	1209	1156	1100	1041	981	918	846	759	639	
1/4			Sones	14.2	13.8	13.4	12.9	12.3	11.7	11.5	11.2	10.8	10.6

Performance certified is for installation type A: Free inlet, Free outlet. Power rating (BHP) does not include transmission losses. Performance ratings do not include the effects of appurtenances (accessories). The sound ratings shown are loudness values in fan sones at 5 ft. (1.5 m) in a hemispherical free field calculated per AMCA Standard 301. Values shown are for installation type A: Free inlet hemispherical sone levels.

Catalog 405, October 2014