

# Stock No. 3ATU1

Job Name: Mark: Submitted By: Date:11/3/2025

CSA Certified Motor

# **Assembled Centrifugal Belt-Drive Upblast Exhaust Ventilator**



Designed for use in restaurants, schools, commercial, and industrial applications to exhaust contaminated air from kitchen range hoods, up and away from the roof. Leakproof, spun aluminum construction features a fully rolled windband for increased stability.

- Aluminum backward inclined, nonoverloading centrifugal wheel design
- Maximum inlet air temperature: 300° F
- NEMA 1 junction box located in motor enclosure
- Optional NEMA 1 and 4 disconnects available
- Sealed pillow block bearings
- UL/cUL 705 Listed for Power Ventilators
- UL/cUL 762 Listed for Restaurant Exhaust Appliances
- Air handling quality bearings meet minimum of L10-100,000 hours






A B C D

Α	В	С	D
26 in	28 7/8 in	26 3/8 in	19 3/8 in

## **Performance Characteristics**



## **Construction Features**

Impeller Diameter (Typ.)	14 3/4 in
Impeller Type	Backward Inclined Centrifugal
Impeller Material	Aluminum
Max Inlet Temp	300 °F
Bearing Type	Sealed Pillow Block
Drive Package Description	Drives Assembled
Warranty Length	1 Year

#### **Motor Information**

Motor Item Number	4YU38
Voltage	208-230/460
Hertz (Cycle)	60 Hz
Motor Phase	3
Motor Enclosure	Open Drip Proof
RPM	1,725 rpm
Full Load Amps	3.4-3.4/1.7

## Other Components

Component	Description	Item #
Fan Description	Exhaust Fan	_
Belt	AX21 (QTY: 1)	3VU40
Driver Sheave	1VL40x5/8	3X264
Driven Sheave	BK45H	3X583
Driven Bushing	H x 3/4	3X573

## **Air & Sound Performance**

Motor HP	Max BHP	Fan RPM	CFM @	0.000" SP	0.125" SP	0.250" SP	0.375" SP	0.500" SP	0.625" SP	0.750" SP	0.875" SP	1.000" SP	1.250" SP	1.500" SP	1.750" SP
1	1.00	1725	CFM	3125	3066	3005	2936	2865	2789	2711	2629	2539	2339	2085	1704
	1.00	1720	Sones	26.0	23.0	22.0	24.0	24.0	18.0	15.1	14.1	13.4	14.3	13.8	13.8

Performance certified is for installation type A: Free inlet, Free outlet. Power rating (BHP) does not include transmission losses. Performance ratings do not include the effects of appurtenances (accessories). The sound ratings shown are loudness values in fan sones at 5 ft. (1.5 m) in a hemispherical free field calculated per AMCA Standard 301. Values shown are for installation type A: Free inlet hemispherical sone levels.

Catalog 405, January 2010

## **Operating Range of Drive Package**

Turns Open	FRPM @ 0 TO	FRPM @ 1/2 TO	FRPM @ 1 TO	FRPM @ 1 1/2 TO	FRPM @ 2 TO	FRPM @ 2 1/2 TO	FRPM @ 3 TO	FRPM @ 3 1/2 TO	FRPM @ 4 TO	FRPM @ 4 1/2 TO	FRPM @ 5 TO
Approx. FRPM	1725	1647	1600	1554	1507	1461	1415	1368	1322	1276	_