Job Name: Mark:

Submitted By: Date:10/30/2025

Standard-Duty Belt-Drive Exhaust Fan




Designed for commercial and industrial applications requiring high volumes of air at low static pressures. Construction includes rigid drive frame rails and one-piece motor/bearing plate. Mount fan in vertical position for exhaust applications or horizontal position for supply applications.

- Variable pitch adjustable motor pulley to optimize fan performance
- 6-Blade reinforced galvanized steel propellers
- Maximum inlet air temperature: 104° F




Dayton Electric Mfg. Co. certifies that the ventilators shown herein are licensed to bear the AMCA seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 211 and AMCA Publication 311 and comply with the requirements of the AMCA Certified Ratings Program.





Performance Characteristics



Construction Features

Impeller Diameter (Typ.)	20 in					
Impeller Type	Propeller					
Impeller Material	Steel					
Number of Blades	6 104 °F					
Max Inlet Temp						
Bearing Type	Sealed Pillow Block Drives By Others					
Drive Package Description						
Warranty Length	1 Year					

Air & Sound Performance

Motor HP	Max BHP	Fan RPM	CFM @	0.000" SP	0.125" SP	0.250" SP	0.375" SP	0.500" SP	0.625" SP	0.750" SP
1/4	0.30	953	CFM	3581	3148	2469	1160	657	_	_
			Sones	16.2	16.2	16.3	16.1	16.0	_	_
1/3	0.40	1039	CFM	3904	3517	2954	2039	1064	603	_
			Sones	17.2	17.2	17.2	17.4	18.4	19.0	_
1/2	0.60	1221	CFM	4587	4277	3873	3333	2514	1456	1064
			Sones	20.0	20.0	20.0	21.0	21.0	23.0	24.0

Performance certified is for installation type A: Free inlet, Free outlet. Power rating (BHP) does not include transmission losses. Performance ratings do not include the effects of appurtenances (accessories). The sound ratings shown are loudness values in fan sones at 5 ft. (1.5 m) in a hemispherical free field calculated per AMCA Standard 301. Values shown are for installation type A: Free inlet hemispherical fan sone levels.

Catalog 405, January 2010